

**PRINCIPALII INDICATORI**

**Extindere retea de alimentare cu apa potabila in localitatea Budurleni, comuna Teaca, judetul Bistrita-Nasaud**

LOCALITATEA BUDURLENI

**Retea distributie**

|                               |         |    |
|-------------------------------|---------|----|
| Conducta PEHD De 110 mm PN 10 | 3000.00 | ml |
| Conducta PEHD De 125 mm PN 10 | 350.00  | ml |
| Conducta PEHD De 160 mm PN 10 | 100.00  | ml |

**Retea aductiune**

|                                 |         |     |
|---------------------------------|---------|-----|
| Conducta PEHD Dn=90 mm Pn16     | 435.00  | ml  |
| Conducta PEHD Dn=140 mm Pn16    | 4880.00 | ml  |
| Conducta preaplin SN4 Dn250 mm  | 300.00  | ml  |
| Grup pompare                    | 2.00    | buc |
| Instalatie de clorinare         | 1.00    | buc |
| Rezervor de inmagazinare 200 mc | 1.00    | buc |

PREȘEDINTE,

SECRETAR,